

PANELBOARD SCHEDULE 'A'										LOCATION: EQUIP. ROOM					
VOLT: 120/240V., 1Ø, 3W MAINS: 200A. M.L.O.										C/B RATING: 22 k.A.I.C.					
										NEMA RATING: 1					
										TYPE: LOAD CENTER					
CIRC. NO.	CIRCUIT DESCRIPTION / LOCATION					C/B	WIRE SIZE	CIRC. NO.	CIRCUIT DESCRIPTION / LOCATION					C/B	WIRE SIZE
1	LTG./RECEPTS - REAR PATIO					20	#12	2	KITCHEN APPLIANCE CIRCUIT					20	#12
3	-					1		4	KITCHEN APPLIANCE CIRCUIT					1	
5	- GREAT ROOM					1		6	REFRIGERATOR					1	
7	-					1		8	FREEZER					1	
9	- FOYER/ENTRY					1		10	DISHWASHER/DISPOSER CKT					1	
11	- EXTERIOR PORTE COCHERE					1		12	DISHWASHER/DISPOSER CKT					1	
13	- HALLWAYS					1		14	RANGE					50	#6
15	- GARAGE					1		16						2	
17						1		18	DOUBLE OVEN					50	#6
19	- PANTRY/NOOK/KITCHEN					1		20						2	
21	SPARE					1		22	HOOD CIRCUIT					20	#12
23	WATER HEATER - GARAGE					30	#10	24	DINING CIRCUIT					1	
25						2		26	U.C. REFRIG. - OFFICE					1	
27	WATER HEATER - SERVANT					30	#10	28	COPIER - OFFICE					1	
29						2		30	LTG./RECEPTS - OFFICE					1	
31	WATER HEATER - MEDIA					30	#10	32	- LAUNDRY/HALL					1	
33						2		34	SMOKE DETECTOR CIRCUIT					1	
35	CLOTHES WASHER					20	#12	36	CLOTHES WASHER					1	
37	CLOTHES DRYER					30	#10	38	CLOTHES DRYER					30	#10
39						2		40						2	

</

PANELBOARD SCHEDULE 'C'										LOCATION: EQUIP. ROOM					
VOLT: 120/240V., 1Ø, 3W MAINS: 200A. M.L.O.										C/B RATING: 10 k.A.I.C.					
										NEMA RATING: 1					
										TYPE: LOAD CENTER					
CIRC. NO.	CIRCUIT DESCRIPTION / LOCATION					C/B	WIRE SIZE	CIRC. NO.	CIRCUIT DESCRIPTION / LOCATION					C/B	WIRE SIZE
1	LTG./RECEPTS - MASTER BEDROOM					15	#14	2	APPLIANCE CKT - GUEST					20	#12
3	- SITTING ROOM					1		4	REFRIGERATOR - GUEST					1	
5	- CLOSETS/HALL					1		6	BEER COOLER					1	
7	- GUEST LIVING					1		8	WINE COOLER					1	
9	- GUEST BEDROOM					1		10	JACUZZI TUB (GFCI C/B)					1	
11	- GUEST PATIO					1		12	RECEPTS - LOW VOLTAGE ROOM					1	
13	- GUEST GARAGE					20	#12	14						1	
15	GARAGE DOOR OPERATOR					1		16	SPACE					1	
17	LIGHTING - MASTER BATH					1		18						1	
19	BATHROOM RECEPT CIRCUIT - MASTER					1		20						1	
21	- POWDER/OFFICE					1		22						1	
23	- GUEST					1		24						1	
25	LTG./RECEPTS - BAR/WINE/HALL					1		26	AIR HANDLER 9.0 FLA					20	#12
27	- OWNER OFFICE					1		28	AIR HANDLER 14.0 FLA					20	#1
29	HOT PLATE					30	#10	30	CONDENSING UNIT 22.3 FLA					40	#14
31						2		32						2	
33	STACK WASHER/DRYER					30	#10	34	CONDENSING UNIT 33.5 FLA					50	#6
35						2		36						2	
37	STACK WASHER/DRYER					30	#10	38	CONDENSING UNIT 33.5 FLA					50	#6
39						2		40						2	

PANELBOARD SCHEDULE 'D'										LOCATION: EQUIP. ENCLOSURE					
VOLT: 120/240V., 1Ø, 3W MAINS: 100/2 M C/B MTG: SURFACE										C/B RATING: 10 k.A.I.C.					
										NEMA RATING: I					
										TYPE: LOAD CENTER					
CIRC. NO.	CIRCUIT DESCRIPTION / LOCATION					C/B	WIRE SIZE	CIRC. NO.	CIRCUIT DESCRIPTION / LOCATION					C/B	WIRE SIZE
1	LTG./RECEPTS - CABANA AREA					20	#12	2	SPARE (GFCI C/B)					20	#1
3	↓					1		4	↓					1	
5	SPARE					1		6	SPARE					20	#1
7	↓					1		8	↓					2	
9	↓					1		10	SPARE					20	#2
11	SPACE					1		12	↓					2	
13	↓					1		14	SPARE					30	#2
15	↓					1		16	↓					2	
17	↓					1		18	SPARE					50	#2
19	↓					1		20	↓					2	
21	↓					1		22	SPACE						
23	↓					1		24	↓						
25	↓					1		26	↓						
27	↓					1		28	↓						
29	↓					1		30	↓						